



Sure Controls  
N981 Tower View Drive  
Greenville, WI 54942

## CERTIFICATE OF CALIBRATION

**Unit Model #:** 195374  
**Unit Serial #:** LG030053G  
**Recorder Serial #:** UR34889-001-014 0306 K28  
**Instrument #:** 29616  
**MAC Address:** 08:00:48:80:73:B0

Sure Controls does hereby certify the above instrument was calibrated against standards maintained by Sure Controls and meets or exceeds all published specifications. The accuracy of these standards is directly traceable to the National Institute of Standards and Technology.

Recorder	Displayed Value		
	Primary Standard Signal 382.0 °F	Primary Standard Signal 882.0 °F	Primary Standard Signal 1382.0 °F
CHANNEL 1	382	883	1383
CHANNEL 2	382	883	1383
CHANNEL 3	382	882	1383
CHANNEL 4	382	882	1383
CHANNEL 5	382	883	1383
CHANNEL 6	382	883	1383

Calibration Date: 3/14/2012

Recalibration Date: 3/14/2013

Certified by: VH

Instrumentation Used: Beamex Model No. MC5 Multi-Function Calibrator  
Beamex Serial No. 25513615MJP  
Sure Controls ID No. STD-035